

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.	:
-----------------	---

IECEx SIR 15.0101X

issue No.:0

Certificate history:

Status:

Current

Date of Issue:

2015-09-24

Page 1 of 3

Applicant:

AW-Lake Company 8809 Industrial Dr

Franksville Wisconsin 53126

United States of America

Electrical Apparatus: Optional accessory:

RT-30Ex Transmitter and HUB-41Ex Adaptor

Type of Protection:

Flameproof

Marking:

Ex d IIB+H₂ T5 Gb

Ta = -40°C to +60°C

Approved for issue on behalf of the IECEx

Certification Body:

A C Smith

Position:

Certification Manager

Signature:

(for printed version)

Date:

2015-09-24

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

SÍRA Certification Service CSA Group Unit 6, Hawarden Industrial Park Hawarden Deeside CH5 3US United Kingdom







IECEx Certificate of Conformity

Certificate No.: IECEx SIR 15.0101X

Date of Issue: 2015-09-24 Issue No.: 0

Page 2 of 3

AW-Lake Company Manufacturer:

8809 Industrial Dr Franksville Wisconsin 53126

United States of America

Additional Manufacturing location

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011 Explosive atmospheres - Part 0: General requirements

Edition: 6.0

Edition: 6

IEC 60079-1: 2007-04

Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report: GB/SIR/ExTR15.0250/00

Quality Assessment Report:

US/ETL/QAR15.0011/00



IECEx Certificate of Conformity

Certificate No.:

IECEx SIR 15.0101X

Date of Issue:

2015-09-24

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

RT-30Ex transmitter

The RT-30Ex is a meter-mounted digital flow monitor housed in a single access enclosure (Ex d connecting head) or dual access enclosure (Ex d 'Universal instrument housing'). A large LCD graphic display provides easy to read indication of flow rate. The enclosure contains 2 printed wiring boards – A display board and a terminal connection board with processor and I/O board. These are interconnected by a ribbon cable. Refer to the Annexe for further information

CONDITIONS OF CERTIFICATION: YES as shown below:

 The meter body temperatures must not exceed 85°C for temperature class T5 for explosive gas atmospheres.

Annex: IECEx SIR 15.0101X Iss 0 Annexe pdf

Annexe to:

IECEx SIR 15.0101X Issue 0

Applicant:

AW-Lake Company

Apparatus:

RT-30Ex Transmitter HUB-41Ex Adaptor

The full description is repeated for clarity.

RT-30Ex transmitter

The RT-30Ex is a meter-mounted digital flow monitor housed in a single access enclosure (Ex d connecting head) or dual access enclosure (Ex d 'Universal instrument housing'). A large LCD graphic display provides easy to read indication of flow rate. The enclosure contains 2 printed wiring boards - A display board and a terminal connection board with processor and I/O board. These are interconnected by a ribbon cable.



RT-30Ex

The Hub Adapter (swivel union assembly) comprises of 4 pieces: the swivel union top, bottom, collar and a sliding probe tube. The Hub Adapter houses the Hall Pickup assembly (wired probe tube pictured below) which is connected to the process pipe per control drawing RT30990 via 3/8"-18 NPT Male threads. The swivel union top connects to the RT-30Ex Transmitter or HUB-41Ex adaptor Flameproof Ex d enclosure via 1/2"-14 NPT Male threads. The top and bottom parts are held together by the swivel collar via a 1 3/8"-18 UNEF 2A/2B threaded union.



HUB Adaptor or 'Swivel Union Assembly' (photo not scaled)

Date: 24 September 2015 Page 1 of 2

Unit 6, Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Sira Certification Service

Group

+44 (0) 1244 670 900 Tel: Fax: Email:

Web:

+44 (0) 1244 539 301 ukinfo@csagroup.org www.csagroupuk.org

Annexe to:

IECEx SIR 15.0101X Issue 0

Applicant:

AW-Lake Company

Apparatus:

RT-30Ex Transmitter HUB-41Ex Adaptor



HUB-41Ex adaptor description

When an Ex d connecting head is assembled to the "swivel union assembly" instead of an Ex d enclosure, the unit becomes a HUB-41Ex Adapter found between a remotely mounted RT-30Ex transmitter and the process pipe. The Ex d connecting head for the HUB-41Ex is identified as model XD-AD by Limatherm (IECEx FTZ 14.0003U).



HUB-41Ex (photos not scaled)

Control drawing RT30990 details several meter body connection options between the equipment and the meter body in the final installation. This control drawing addresses the minimum partition wall thickness, meter body connecting threads and alternative welding found under pressure. Two Styles of sensor ports are identified in the control drawing each rated for a Maximum Process Pressures within the meter body.

Conditions Of Manufacture

i. The equipment incorporates previously Ex d certified enclosures, as shown in the table below. It is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with this device, and the manufacturer shall inform CSA Sira of any modifications of the device that may impinge upon the explosion safety design of the product.

Part number	Description	Certificate Number	Applicable requirements
XD-ID100win XD-ID100 XD-100H XD-ID100Hwin	"Universal instrument housing" two compartment aluminium enclosure with interconnecting port, one window cover and one blank cover	IECEx FTZ 10.0019U	
XD-I XD-Iwin XD-IH XD-IHwin XD-ILwin	"Universal instrument housing" aluminium enclosure with single internal compartment, one window cover and one blank cover	IECEx FTZ 12.0017U	Ed. 6 of IEC 60079-0 Ed. 6 of IEC 60079-1
XD-AD	"Connecting head" Aluminium enclosure with one blank cover	IECEx FTZ 14.0003U	

- ii. Each manufactured meter body, identified in control drawing RT30990 Rev F approved 14 July 2015, must withstand a pressure test of 1.5 times the maximum working pressure.
- iii. The meter body must have the sensor port manufactured according to Control Drawing RT30990 Revision level F, including construction material as noted on the drawing. The end user must be supplied with this control drawing RT30990 for proper installation of the sensor.

Sira Certification Service

Unit 6, Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670 900
Fax: +44 (0) 1244 539 301
Email: <u>ukinfo@csagroup.org</u>
Web: <u>www.csagroupuk.org</u>

Form 9530 Issue 1

Date:

24 September 2015

Page 2 of 2