

	CUSTOMER CONNECTIONS				
ITEM	DESCRIPTION	SIZE (100 PSI TRIM)	SIZE (15 PSI TRIM)	TYPE	
Α	FEED WATER INLET	1/2"	1/2"	N.P.T.	
В	BLOWDOWN OUTLET	1"	1"	N.P.T.	
С	STEAM OUTLET	1"	1"	N.P.T.	
D	WATER COLUMN DRAIN	1"	1"	N.P.T.	
Е	SAFETY RELIEF VALVE	1"	3/4"	N.P.T.	

EQUIPMENT SPECIFICATION CHART				
TYPE:	ELECTRIC			
MAX ALLOWABLE WORKING PRESSURE:	100 PSI			
BOILER OUTPUT:	163,693 BTU/HR			
STEAM OUTPUT/MIN. SRV CAPACITY:	169 LBS/HR			
NUMBER OF ELEMENTS (WATTAGE PER ELEMENT):	1 (12 kW), 2 (18 kW)			
WATER CAPACITY (OPERATING):	9 GAL.			
APPROXIMATE DRY WEIGHT:	356 LBS.			
APPROXIMATE OPERATING WEIGHT:	431 LBS.			
APPROXIMATE SHIPPING WEIGHT:	360 LBS.			
APPROXIMATE FLOODED WEIGHT:	475 LBS.			

ELECTRICAL REQUIREMENTS			
VOLTAGE	OPERATING FLA		
208/60/3	134 AMPS		
240/60/3	116 AMPS		
380/60/3	73 AMPS		
480/60/3	59 AMPS		
600/60/3	47 AMPS		

NOTE: OPERATING FULL LOAD AMPERAGE (FLA) REFERS TO THE BOILER'S RATED CURRENT DRAW

- 1. STEAM OUTPUT LB/HR: FROM 0 PSIG AT 212°F (0 KG/CM² AT 100°C)
- 2. ALL CLEARANCES ARE FACTORY RECOMMENDATIONS. CONSULT LOCAL JURISDICTION FOR EXACT CODE COMPLIANCE.
- 3. FULTON RECOMMENDS MINIMUM CLEARANCE OF 36" IN FRONT OF ELECTRICAL PANELS AND 24" AROUND SIDES OF BOILER.
- 4. PLEASE REFER TO THE O&M MANUAL FOR ADDITIONAL INFORMATION REGARDING CLEARANCES AND INSTALLATION INSTRUCTIONS.
- 5. ALL DIMENSIONS INSIDE ( ) DENOTE REFERENCE DIMENSIONS.
- 6. ALL DIMENSIONS INSIDE ☐ DENOTE OVERALL DIMENSIONS.
- 7. WE RESERVE THE RIGHT TO CHANGE SPECIFICATIONS AND/OR DIMENSIONS. ALL INFORMATION IS SUBJECT TO CHANGE BASED ON ADDITION OF ANY OPTIONAL EQUIPMENT AND/OR ACCESSORIES. PLEASE CONSULT THE FACTORY FOR PROJECT SPECIFIC ESTIMATES IF ADDITIONAL OPTIONS OR ACCESSORIES ARE REQUIRED.
- 8. SAFETY RELIEF VALVE SIZING IS BASED ON 100 PSIG TRIM. OTHER TRIM PRESSURES WILL CHANGE SAFTEY VALVE SIZE.

exclusive property of fulton Group N.A., Inc. BOILER (100 PSI DESIGN) INITIAL RELEASE LEC. ENG: Fulton Group N.A., Inc. he corporation does no permit their use except with prior written conse O.M. REVIEW APPROVED BY REV REVISION DESCRIPTION B.O.M. ELEC. ENG MECH. ENG CHECKED APPROVED WW

1 OF 1

7/29/2016

Fulton Group N.A., Inc 972 Centerville Road Pulaski, New York USA 13142



9-FBE-048PDS

SHEET 1 OF 1