



Notes:

1. Fuel is standard natural gas.
2. 20 °F temperature differential.
3. Thermal efficiency values obtained using modified methodology from the BTS-2000 test procedures.
4. There are two major Endura boiler operating conditions which directly affect thermal efficiency:
 - a. Return Water Temperature: As return water temperature decreases, thermal efficiency increases.
 - b. Firing Rate (% Input): As firing rate decreases, thermal efficiency increases.
5. See Installation and Operation Manual for turndown configuration.